



GOVERNMENT OF TRIPURA
**DIRECTORATE OF FIRE & EMERGENCY
SERVICES**
AGARTALA : TRIPURA



Phone: 0381-232-6451

Email: dg.fire-tr@gov.in

website:www.fireservice.tripura.gov.in

No: FSRTFES/2026/00056

Dated: 17/03/2026

To,
Mallika Debbarma
Bishalgarh, Sepahijala
Madhupur B.O - 799102

Sub: **Fire Safety Recommendation** For Application Reference No **FSRTFES/2026/00056** .

With reference to your Application Reference No FSRTFES/2026/00056 Dated 26/02/2026 Fire Safety Recommendation on fire prevention and fire safety measures of the following building/premises is hereby issued in accordance with the conditions laid down in the relevant portions of Part-IV of the latest National Building Code and the Tripura Building Rules.

Name of the Applicant:	Mallika Debbarma			
Name of Owner with Plot details:	S. No.	Owner Name and Address		
	1.	দং শিক্ষা বিভাগ কর্তৃক রক্ষিত জাতি: সাধারণ		
	S. No.	Plot No	Total Area	Classification
	1.	1025	0.6	টিলা
	2.	2866	2.7	----
	3.	4145	3.54	----
	4.	4146	1.22	টিলা
	5.	4147	0.18	টিলা
	6.	4148	0.38	টিলা
	7.	4151	0.38	লুঙ্গা
8.	989	0.2	টিলা	
Name of the Property/ Organization/ Commercial establishment	Madhupur H S School			
Address of the Building/ Premises:	South Madhupur Habitation, Madhupur Gram Panchayat, Bishalgarh Block, Post Office Madhupur B.O - 799102, Sepahijala District, Tripura.			

A Fire Safety Certificate (FSC) will be issued, subject to verification of compliance of fire prevention and fire safety measures on which the fire safety recommendations enumerated in the attached letter and further submission of application through online system.

Director,
Fire & Emergency Services,
Or Authorized Signatory
Tripura : Agartala

***** WE SERVE TO SAVE*****

This certificate shall not be used by the Insurance service provider

Fire Safety Advisory and Suggestion:

- 1. Road width -6 (six) Meters (Exist).
- 2. Gate width -6 (six) Meters (Exist)
- 3. Width of approach road 6 Meters (Exist)
- 4. No. 2 staircase per upper floor.
- 5. 1.5 Meters width of staircase upper floors
- 6. No.1 staircase continuous to terrace.
- 7. 2.64 width of corridor
- 8. 2 nos. of CO2 Extinguisher having capacity 2 KG to be installed in each 15 meters distance each floor and CO2 Extinguisher 4.5 kg of capacity to be installed nears the electric panel board .
- 9. 2 nos. ABC type fire extinguisher with a capacity of 6 kg to be installed at a distance of 15 meters each floors.
- 10. 2 nos. DCP type fire extinguisher with a capacity of 6 kg to install at a distance of 15 meters each floors.
- 12. Length of hose reel hose is to be 30 meters.
- 13. Hose reel nozzle diameter is to be 19 mm
- 14. An alternative source of power supply should be provided
- 15. 3 nos. hooters with battery backup to be installed at the each floor.
- 16. 3 nos. manual call points (MCP) with battery back up to be installed in each floor.
- 17. Down comer system to be installed in the building with mild steel pipes dia not less than 100 mm/4 inch in diameter and 4.5 mm in thickness B-class and Size of riser 100 mm
- 18. 3 nos. of landing valve to be provided at hose reel point and 2(two) way inlet valve at the building.
- 19. 2 nos. of double door hose box contains with 2 nos. branch pipe and 4 nos. of 15 meter length canvas hose is to be installed near the hose reel point.
- 20. Terrace level fire pump with a discharge capacity of 450 LPM (MONOBLOC), with minimum pressure of 3.5 kg/cm² to be installed.
- 21. Terrace level head of pump is to be 70m
- 22. Terrace level power supply should be in 3(three) phases to be provided.
- 23. Auto pump controller to be installed in the terrace level pump along with pressure gauge, pressure switch and air released valve to be installed on the terrace of the building
- 23. Auto pump controller to be installed in the terrace level pump along with pressure gauge, pressure switch and air released valve to be installed on the terrace of the building
- 24. Terrace tank capacity having of 5,000 liters to be constructed in the building exclusively for fire fighting purpose always to be kept full of water.
- 25. Exit/Entry signage is to be provided in the building.
- 26. Standby power supply should be provided.
- 27. Trained person should be appointed to operate the fire fighting equipments in case of any emergency.
- 28. Unused combustible/inflammable materials and explosive substances should not be stored anywhere in the building. 29. Fire extinguisher /down comer/Hose reel hose should not be installed near the staircase landing. 30. Exhaust fan after 3 meter to be installed all building area. 31. Electric diagram showing separate circuits of fire and life safety measures diagram will be used to verify, relevant compliance with national building code, IS-1645, and for functional tests of fire safety related equipment. Certificate of compliance with electrical rules and the diagram is to be signed by the electrical contractor, which is to be submitted/Uploaded at the time of applying for NOC online.

NB:-Issued

Digitally signed by MEGHA JAIN
Date:17-03-2026 17:40:22 PM